ITEM 11579-19	Project **Student Accommodation Upper Queen Street**	Package **Passive Fire Protection**	Client **Watts & Hughs**	Status **Submitted**

Location	
Location No.	283
Drawing Reference	LEVEL 1

Specification	
Specification	Ryanfire SL Collar - PVC Pipe
Site Instruction No:	
Specification Files	• V22.10





Job Item	
Item No.	11579-19
Type of Work	Contract
Floor Level	LEVEL 1
Service Type	Hydraulic
FRR	-/30/30
Before Photo	
After Photo	
Materials	• Ryanfire - SL-160mm: Quantity: 1 • Ryanfire Mastic: Quantity: 1 • Tomahawk FastFix - 6.5 x 32mm: Quantity: 3

Job Item	
Photo of Sticker	
Comments	
Timestamp	7:54am on Tue 11 Oct 2022

Operative	
Name	Paul Jayson Mendoza